

Acknowledgement of Addendum 1 Issued October 2, 2018, by email and posted to the website.

Addendum 1 – The written questions submitted on or before September 24, 2018.

Firm Name: _____ **Date:** _____

Signature: _____ **Title:** _____

Typed/Printed Name: _____

The COMET reserves the right to make modifications or amendments to this RFP, either at the request of an Offeror or upon The COMET's own initiative. If The COMET determines it is appropriate to revise any portion of this RFP, it will issue a written amendment to the RFP. Offerors are required to submit a signed copy of the "Receipt of Amendments" for each amendment issued with their proposals.

This Amendment 1 is hereby issued to answer the following questions and makes amendments to the RFP as identified in the answers to questions as follows:

With this being a three-year contract and the number of shelters projected to be ordered, there are additional federal clauses that need to be added to Appendix D. The additional clauses that were added are Buy America; Resolution of Disputes, Breaches or Other Litigation; Clean Air and Clean Water. These clauses are attached as supplemental Appendix D and will need to be signed and included with each proposal.

Question 1: Will the new shelters be installed on new concrete pads or existing? If using existing concrete pad what are the dimensions, length, width, depth and if there is any steel reinforcement in the pads.

The shelters and amenities will be installed on new concrete that is 6" thick. The size will be dictated by the shelters, benches, and other amenities installed at the site.

Question 2: Solar Security Lighting

- Light output at ground level (Lux)
- Autonomy of the system
- Operation lighting time (dusk to dawn)

We are seeking a fully autonomous low voltage solar light system. The lights should turn on at dusk and off at dawn (if still retaining power; all night operations are not required but desirable)

Question 3: Solar powered Ad Box -

- Light output at the diffuser (Lux)
- Autonomy system
- Illumination time per day/night

We are not requesting lighted ad panels.

Question 4: Who will unload the delivered shelters?

We have a forklift on site. There is usually a person licensed to drive the forklift available.

Question 5: What kind of dimensions are looking for the chopping cart corral?

Please see picture attached.

Question 6: Shelter, small footprint. What class are you looking for? 16ft or 30ft?

Somewhere between 8 and 12 feet.

Page 12 - Can Central Midlands Transit provide the COMET logo file, so that bidders can include the artwork in their designs for submittal of the proposal? If this is possible, an .eps or other "vector" file type is preferred.

The EPS file is attached.

Page 13 - Street Furniture List - There is no mention of lighting for the shelters or stops. Does the COMET desire solar or electric lighting in any of the shelters, and if so please provide the specifications desired.

The shelters should have some type of solar light kit included. Please see question 2 above for specifications.

Please remember all questions need to be submitted in writing and addressed to Virginia Goodson at Virginia.goodson@catchTheCOMET.org or Virginia Goodson, 3613 Lucius Road, Columbia, SC 29201.